



Bristol Kendall Fire Department

FIRE PREVENTION BUREAU

103 East Beaver Street
Yorkville, IL 60560-1704
Phone: 630-553-6186
Fax: 630-553-1482

FIRE PROTECTION SYSTEMS REQUIRED TESTING

All fire protection systems shall be tested yearly or twice a year depending on their requirements. IFC 901.6 states” *Fire detection, alarm, and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Non-required fire protection systems and equipment shall be inspected, tested and maintained or removed.*”

Fire protection systems shall be inspected, tested and maintained in accordance with the referenced NFPA standards listed below:

Portable Fire Extinguishers NFPA 10. Annually
Carbon dioxide fire extinguishing system NFPA 12. Annually
Dry Chemical extinguishing systems NFPA 17. Annually
Wet chemical extinguishing system NFPA 17A. Annually
Water Based fire protection systems NFPA 25. Annually
Fire Alarm Systems NFPA 72. Annually
Clean Agent extinguishing systems NFPA 2001. Annually
Any of the above systems that are protecting a Class 1 hood, in a commercial kitchen shall be tested semi-annually

Yearly reports from your testing service shall be forwarded immediately to the Fire Prevention Bureau. Any deficiencies listed therein will require immediate repairs.

When a system is out of service, the Fire Prevention Bureau shall be notified immediately as to the time frame the system will be down.

If you have any question or need further assistance call the Bristol Kendall Fire Prevention Bureau. 630-553-6186 ext 119.